Fats, Oil and Grease (F.O.G.)

Sanitary Sewer Overflows (SSO's)

The <u>number one</u> cause of blockages and SSO's in wastewater collection systems is discharges containing high concentrations of FOG from Food Service Establishments.



In the Report to Congress, EPA estimates that between 23,000 and 75,000 SSOs occur each year in the United States, resulting in releases of between 3 billion and 10 billion gallons of untreated wastewater. These events take place throughout the United States.









National Pretreatment Program

(40 CFR 403)



Controlling Fats, Oils, and Grease Discharges from Food Service Establishments

The National Pretreatment Program already provides the necessary regulatory tools and authority to local pretreatment programs for controlling interference problems. Under the provisions of Part 403.5(c)(1) & (2), in defined circumstances, a POTW must establish specific local limits for industrial users to guard against interference with the operation of the municipal treatment works. See 46 FR 9406 (28 January 1981).

Refer to the link

http://www.pmairegs.com/sewer/

to assist you in getting the proper requirements.

They have the backing of the EPA.

They are typically referred to as the AHJ.

Regulatory Resource Center

Sewer Discharge Limits

PMA

Home

Air Regs

Sewer Discharge

Solid Waste

Transportation

Safety

Passport

Training

Silver Council

Sewer Home

SEWER DISCHARGE LIMITS


FIND:

State/Province:

City/Town:

Search

Welcome to the PMA Sewer Discharge Limits database. Here you will find a comprehensive catalog of sewer discharge ordinances from all North American towns and cities. Please select your State/Province and/or enter the City of interest.



Regulatory Resource Center

Sewer Discharge Limits

Home

Air Regs

Sewer Discharge

Solid Waste

Transportation

Safety

Passport

Training

Silver Council

Sewer Home

FIND:

State/Province:



City/Town:

Search

SEWER DISCHARGE LIMITS

Essential EHS

Search Results

10 cities found. Click on a city for ordinance details.

CITY	STATE	POP	BYLAW#	DATE
Concord	NH	41823	2292	2-8-1999
<u>Derry</u>	NH	20446	sewer use	2-7-1996
<u>Dover</u>	NH	28216	within data	
<u>Hillsborough</u>	NH	1826	NA	
<u>Hudson</u>	NH	7626	097-01	8-26-1997
<u>Manchester</u>	NH	108871	NA	1-17-1995
<u>Nashua</u>	NH	87285	NA	1-1-1997
<u>Newington</u>	NH	900	sewer use	4-1-2000
<u>Portsmouth</u>	NH	21002	NA	
<u>Rochester</u>	NH	29654	sewer use	12-7-1999

State/Provin	nce:
	~
City/Town:	
S	earch

EssentialEHS

Ordinance Data

City/Town: Manchester

Address: City of Manchester

300 Winston Street

State: NH

Zip: 03103-6826

Population: 108871

Contact: Rick Cantu

Position: Industrial Pretreatment Supervisor

Phone: 4 603-624-6513 0

Fax: 603-628-6234

Ordinance: NA

Ord. Date: 1-17-1995

Email:

Website: Click here



Restricted Discharges to Sanitary Sewer

Maximum Temp:

pH Low: 5.0

pH High: 11.5

Synthetic Oils/Grease: 100

Natural Oils/Grease: 350

Phosphorous (P):

Kjeldahl Nitrogen (KN):

Phenolics:

BOD: 350

Suspended Solids (SS): 350

COD:

Layers:

Dyes:

Aluminum (Al):

v 92 /al

Manchester Ordinance Details:

§ 52.026 Prohibited Discharges.

No person shall discharge or cause to be discharged any of the following described water

or wastes to any public sewer or drain:

(A) Any gasoline, benzene, naptha, fuel oil, or other flammable or explosive liquid, gas, or solid, or any substance which may generate or form any flammable, explosive, or combustible substance, fluid, gas, vapor, or mixture when combined with air, water, or other substances commonly found in sewers. This includes, but is not limited to, pollutants which cause an exceedance of 10% of the lower explosive limit (LEL) at any point in the POTW or wastes with a closed cup flash point in the POTW or wastes with a closed cup flash point of less

than 140°F or 60°C, using the test method specified in 40 CFR 261.21.

(B) Any waters or wastewaters that either independently or by interaction with other wastewaters, pass through or cause

Exterior Grease Interceptor Design



National Pretreatment Program

(40 CFR 403)



Controlling Fats, Oils, and Grease Discharges from Food Service Establishments

Proper design, installation, and maintenance procedures are critical for these devices to control and capture the FOG. For example,

- Interceptor/collector devices must be designed and sized appropriately to allow FOG to cool and separate in a non-turbulent environment.
- FSE must be diligent in having their interceptor/ collector devices serviced at regular intervals.

* Ref. Report by Stone Environmental funded by the Wastewater Management Division, Dept. of Environmental Conservationm Vermont Agency of Natural Resources, Grant #EC-WW-05

Several studies were reviewed which used observation and sampling of field conditions (See Appendix A). In these studies, several similarities stand out. The sample data indicates that undersized interceptors or traps performed very poorly when compared to effluent quality guidelines. Only properly sized, outdoor grease interceptors provided acceptable effluent quality. For example, the city of Austin, Texas study concluded that retention time was the single most important factor in grease removal, and that large volume outdoor grease interceptors are required for acceptable retention times.

Care must be taken when comparing studies and testing methods evaluating the efficiency of FOG removal. Actual wastewater usually contains various emulsifying chemicals, and the mixture is agitated before discharge to the trap or interceptor. While it would be impractical to evaluate all the variables that make up wastewater, it is important to remember that increasing the retention time (by increasing size) allows time for the FOG's to separate.

Effluent Discharge Criteria

Regulatory bodies set different effluent discharge limits all around the country. Presently, there is no one recognized maximum allowable level of AVFOG discharge, although the different values are relatively similar. These similarities can provide the basis for one standard that satisfies all regulatory bodies. (If your local authority is not listed here and it publishes a maximum discharge standard, please forward it to NPCA for consideration in future updates to this paper.)

Some examples of jurisdictions which have stated measurable maximum allowable grease discharge requirements are as follows:

U.S. E.P.A.	150mg/l
Dallas, Texas	200mg/l
Toronto, Ontario	150mg/l
Austin, Texas	200mg/l
Fort Wayne, Indiana	200mg/l
Kansas City, Mo.	200mg/l
Stockton, Ca.	200mg/l

What standards does my grease trap or grease interceptor have to meet?

Grease traps must meet specific standards for design, sizing and installation. These include the International Plumbing Code, PDI G-101, ASME A112.14.3 and, where applicable, ASME A112.14.3. Information about these standards is available from the Industrial Wastewater Pretreatment Program Office.

Grease interceptors should be designed by a professional engineer (P.E.) licensed by the State of New Hampshire. Standard design information is available from the Industrial Pretreatment Program Office for reference. Both the device itself and its installation must be approved by the Seabrook Sewer Superintendent. Grease interceptors must have either two or three chambers, a downstream sampling manhole, and a rated retention time of at least 24 minutes at maximum flow. They must also be configured so as to allow thorough cleaning and inspection without the need for confined space entry.

Both grease traps and grease interceptors must be installed in accordance with manufacturer's instructions.

Table 10-3 Gravity Grease Interceptor Sizing

DFUs (1)	Interceptor Volume (2)	
8	500 gallons	
21 (3)	750 gallons	
35	1,000 gallons	
90 (3)	1,250 gallons	
172	1,500 gallons	
216	2,000 gallons	
307 (3)	2,500 gallons	
342	3,000 gallons	
428	4,000 gallons	
576	5,000 gallons	
720	7,500 gallons	
2112	10,000 gallons	
2640	15,000 gallons	
0 11 BEST 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		

Notes


- The maximum allowable DFUs plumbed to the kitchen drain lines that will be connected to the grease interceptor.
- (2) This size is based on: the DFUs, the pipe size from this code; Table 7-5; Useful Tables for flow in half-full pipes (ref: Mohinder Nayyar Piping) Handbook, 3rd Edition, 1992).
- (3) Based on 30-minute retention time (ref.: Metcalf & Eddy, Inc. Small and Decentralized Wastewater Management Systems, 3rd Ed. 1998). Rounded up to nominal interceptor volume.

TABLE 10-3 Gravity Interceptor Sizing

Pipe Dia. (1)	Full Pipe Flow (nominal) (2)	Interceptor size based on 30 minute retention time. (3) Rounded up to the next nominal size.
2"	19.44 gpm	750 gallons
3"	58.67 gpm	2000 gallons
4"	125.77 gpm	4000 gallons
5"	229.75 gpm	7500 gallons
6"	375.47 gpm	15000 gallons

- (1) For interceptor sizing by fixture capacity see the example below.
- (2) "(.240)slope per foot based on Mannings formula with friction factor N=.012; CAST IRON SOIL PIPE AND FITTINGS HANDBOOK; Ch. 8, Flow Theory And Capacity; pp: 130 134 [Full Pipe]; Cast Iron Soil Pipe Institute (CISPI); 5959 Shallowford Road, Suite 419; Chattanooga, Tn. 37421.
- (3) Based on 30 minute retention time (ref.) Metcalf & Eddy, Inc. 3rd Ed. Small and Decentralized Wastewater Management Systems, 1998) and rounded up to nominal interceptor volume.

GRAVITY INTERCEPTOR SIZING USING FIXTURE CAPACITY




Passive Grease Interceptor Flow


Access Manway Inlet Diffusion Accumulated FOG Baffle Outlet Downcomer



Factory welded inlet, outlet, and baffles to eliminate grease interceptor mal-functions such as broken PVC inlet/outlet tees.










Caption: view of a grease trap outlet "T" showing the grease build up on the wall of the pipe













Engineered to retain wastewater long enough to all fats, oils, and grease to cool down, congeal and separate, while allowing solids to settle.











Installation Photos





















OPTIONS


How it Works

Reading Down – Sludge Level 2 Transducers Reading up – Scum Level **AIR INLET OUTLET** TEE TEE **LIQUID**

Venting



Engineered Systems



























Thank You

Chas Tevis
Highland Tank